

[Skip to main content](#)



[Find an energy certificate](#)

- - English
 - Newid yr iaith ir Gymraeg [Cymraeg](#)

Energy performance certificate (EPC)

Certificate contents

[Energy rating and score](#)

[Breakdown of property's energy performance](#)

[How this affects your energy bills](#)




[Impact on the environment](#)

[Steps you could take to save energy](#)

[Who to contact about this certificate](#)

[Other certificates for this property](#)

Share this certificate

-  [Email](#)
-  [Copy link to clipboard](#)
-  [Print](#)

11 Mallard House, Watersedge
Sligo Road
Enniskillen
BT74 7NY

Energy rating

B

Valid until

30 July 2033



Certificate number
2644-5064-0203-4647-4200

Property type
Top-floor flat
Total floor area
165 square metres

Energy rating and score

This property’s energy rating is B. It has the potential to be B.

[See how to improve this property’s energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		
55-68	D		
39-54	E		
21-38	F		
1-20	G		

The graph shows this property’s current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

- the average energy rating is D
- the average energy score is 60

Breakdown of property’s energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Good
Roof	Pitched, 200 mm loft insulation	Good
Window	Fully double glazed	Good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	(another dwelling below)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 96 kilowatt hours per square metre (kWh/m²).

► About primary energy use

How this affects your energy bills

An average household would need to spend £1,458 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could save £0 per year if you complete the suggested steps for improving this property's energy rating.

This is based on average costs in 2023 when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment

This property's environmental impact rating is B. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces
6 tonnes of CO₂

This property produces
2.8 tonnes of CO2

This property's potential production
2.8 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

The assessor did not make any recommendations for this property.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name
Patrick Maguire
Telephone
07800566263
Email
patepc@live.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme
Stroma Certification Ltd
Assessor's ID
STRO002691
Telephone
0330 124 9660
Email
certification@stroma.com

About this assessment

Assessor's declaration
No related party

Date of assessment

24 July 2023

Date of certificate

31 July 2023

Type of assessment

► Show information about the RdSAP

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.



Support links

- [Help](#)
- [Accessibility](#)
- [Cookies](#)
- [Give feedback](#)
- [Service performance](#)

OG All content is available under the [Open Government Licence v3.0](#), except where otherwise stated
[© Crown copyright](#)